



# Cherokee Electric Cooperative

P.O. DRAWER 0 • 1550 CLARENCE CHESTNUT BY-PASS • CENTRE, AL 35960  
PHONE: 256.927.5524 • TOLL FREE: 1.800.952.2667 • FAX: 256.927.6704

## REQUIREMENTS FOR UNDERGROUND SERVICE

### INSTALLATION BY CUSTOMER

#### **DITCH MUST BE INSPECTED BEFORE CLOSING!**

1. The cooperative will install an underground service to an applicant who meets the following requirements:
  - A. 200 AMP single phase service to single family dwellings, houses and/or double-wide mobile homes, duplex apartment buildings, or commercial accounts up to a maximum of 200 feet for an aid-to-construction charge of \$200.00. The customer will be required to open and close the ditch and install 2 1/2" Schedule 40 PVC conduit from the meter base to a point designated by the Cooperative.
  - B. For 400 AMP single phase and three phase underground services, up to a maximum of 200 feet for an aid-to-construction charge of \$400.00. The customer will be required to open and close the ditch and install (1) run of 3 1/2" Schedule 40 conduit from the meter base to a point designated by the Cooperative.
  - C. For 600 AMP single phase and three phase underground services, up to a maximum of 200 feet for an aid-to-construction charge of \$600.00. The customer will be required to open and close the ditch and install (2) runs of 3 1/2" conduit in the same ditch from the meter base to a point designated by the Cooperative. See attached drawing.
  - D. For services larger than 600 AMP, the aid-to-construction will be \$1.00 per AMP. (800 AMP, \$800.00, 1000 AMP, \$1,000.00)
2. When multiple or gang meter bases are required, they must meet Cooperative standards and be supplied by the developer.
3. Anyone desiring to change an existing overhead service to underground service will pay \$600.00 plus retirement of overhead. If rewiring to 400 AMP underground service will pay \$800.00 plus retirement of overhead. The cost of retiring existing overhead service will be \$50.00. The cost of retiring existing overhead service with pole will be \$250.00.
4. The opening and closing of the ditch for an underground service, underground secondary and/or underground primary shall meet the following specification:

For a 200 amp service, the ditch must be a minimum width of 6 inches and a depth of 30 inches. For a 400 amp or 600 amp service, single phase or three phase, the ditch must be a minimum width of 12 inches and a depth of 30 inches. All conduit shall be Schedule 40 electrical grade, gray in color, no white shall be used. All 90 degree bends shall be Schedule 40 electrical grade, gray in color and shall be 36 inch radius, no 18 inch or 24 inch radius will be accepted. It is also required that a pull string be placed in the conduit by which the service wire can be pulled through the conduit. (The cooperative will furnish a pull string for customer to install.) Warning tape shall also be required to be placed in the ditch providing a distance of approximately 18 inches from the warning tape to the service. Approximately 12 inches of dirt should cover the warning tape. (The cooperative will furnish warning tape at the time of inspection.)

If the cooperative, upon inspection, finds that the specifications mentioned above have not been met, the construction crew will not perform any work until the ditch meets the specifications. This applies to all ground conditions, dirt, rock, tree roots, etc.

5. The customer will be responsible for notifying, marking and exposing all obstacles that may be in harms way of the installation process. (Example: septic tanks, field lines, water lines, gas lines, etc.) No underground service, secondary, and/or primary shall be installed under septic tank field lines or within 5 feet of septic tanks, per health department.
6. The customer will be responsible for any damage incurred due to the improper notification of part 5 of this policy.
7. The customer will be responsible for removing concrete foundation under meterbase.
8. Where disconnect is required at meterbase, it will be mounted on the right side of the meterbase.
9. Ground rods installed 18 to 24 inches to one side of the meterbase.
10. The customer will be responsible for signing forms stating he/she is aware of the contents of this policy.
11. For conditions where the customer has problems reaching the proper depth of ditch for underground service and/or secondary, contact the Engineering Department of Cherokee Electric Cooperative for additional cover requirements. No provisions shall be made for reaching the proper depth of ditch for underground primary!

---

Cherokee Electric Cooperative

---

Cherokee Electric Cooperative Member

---

Service Order Number

